

**ADDENDUM NO. 1**

**August 17, 2010**

**Engineer:**

Parametrix  
1231 Fryar Avenue  
P.O. Box 460  
Sumner, Washington 98390

**Owner:**

City of Sumner  
1104 Maple St,  
Sumner, WA 98390

**24<sup>TH</sup> STREET STORM DRAIN CROSSING**

**CIP 08-02**

To: All Holders of the Bidding Documents, Contract Specifications, and Construction Drawings

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents, Contract Specifications, and Construction Drawings for the opening date of August 20, 2010

Acknowledge receipt of this addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification. This addendum consists of:


<u>2</u>	Pages of text (including this cover sheet)
<u>0</u>	Drawings

Prepared by:   
Charles T. Hill, Associate City Engineer

---

**CITY OF SUMNER**

**Approved for Construction**  
**City of Sumner Public Works Department**

By:   
Mike Dahlem, City Engineer

8-17-10  
Date

## ADDENDUM NO. 1

### REVISIONS TO CONTRACT DOCUMENTS

#### SPECIAL PROVISIONS

##### 1. Section 7-04.3(1)H – Jacking and Boring

- a. Page SP-44: DELETE “The PVC carrier pipe shall be green, DR 51 C905 PVC pipe. All C905 PVC pipe joints restrained with Ring-Tite joints or approved equivalent” and replace with the following:

“The PVC carrier pipe shall be of any color, DR 51 C905 PVC pipe. All C905 PVC pipe joints shall be Ring-Tite joints or approved equivalent”